

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7161-0972:100 Page 1 of 1

**CATEGORY:** Cables-Fire Protective Signaling

**LISTEE:** Atlas Wire & Cable, 133 S. Van Norman Rd., Montebello CA 90640  
Contact: Tony Sanders \*(323) 723-2401 FAX (562) 692-5176

**DESIGN:** Model FPL, FLPR and FPLP power limited fire protective signaling cables.

Conductors: Two or more conductors

Insulation: Solid SRPVC, North America Plastics, Grade "NORPLAS" 21570 and/or Gitto/Global Corp, grade GA-8705-03P, Synergistics, Grade 1360-1021-PID.

Shield: Polyester film bonded to a aluminum foil; serving, wrap or braid of aluminum wire or of metal-coated or uncoated copper wire (optional).

Jacket: PVC, North American Plastics, Grade "NORPLAS" 882A or Gitto/Global Corp., Grade GA-8705-03, or Senergistics, Grade 1690-1060 PJD.

Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances, NEC Article 760, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, Type "FPL", "FPLR", "FPLP", and UL label.

**APPROVAL:** Listed as power-limited fire protective signaling cables.

\*Rev. 03-15-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**